PLANNING AND CODES ADMINISTRATION DEPARTMENT **220 SE GREEN STREET** LEE'S SUMMIT, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161058, Building Permit - Commercial Address: 1200 SE HAMBLEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Underslab Plumbing Mike Copeland **Partial** Wednesday, February 15, 2017

Inspection -Commercial

Partial Correction

THE FOLLOWING AREAS AREA A: BATHROOMS AND FLOOR DRAIN, MOP SINK, STORM

ARE APPROVED DRAIN APPOVED. HARDENED ROOM YET TO BE SET.

AREA B: MECHANICAL CLOSET, STORM NEXT TO MECH ROOM

AND FLOOR DRAINS APPROVED.

AREA C: LOCKER ROOM PLUMBING APPROVED

Partial Correction

4" GREASE LINE FROM G LINE TO N LINE APPROVED 2 Misc 1

Underground Electrical Mike Copeland **Partial** Wednesday, February 15, 2017

Inspection -Commercial

Partial Correction

1 THE FOLLOWING AREAS -PRIMARY CONDUITS FROM TRANSFORMER PAD TO BUILDING

ARE APPROVED **APPROVED**

> -NORTH PARKING LIGHTING APPROVED -SOUTH PARKING LIGHTING APPROVED -WEST PARKING LIGHTING APPROVED

-DUCT BANK FROM HARDENED ROOM TO WEST LOCATION

APPROVED

Partial Correction

ARE APPROVED

2 THE FOLLOWING AREAS NO ISSUES FOUND ON TRENCHED PVC ELECTRICAL CONDUIT:

> FROM GENERATOR LOCATION: ONE 1" N/NE TO L.P. AT N EDGE OF DETENTION POND; ONE 2" + THREE 1' NE TO J.B. @ GATE

CONTROLLER; FIVE 1" NW TO FUEL PUMP LOCATION

Partial	Correction
3	Misc 1

LIGHT POLE BASES APPROVED

DUCT BANK TO GENERATOR PAD 60 FEET APPROVED

Comments: