

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20162554, Building Permit - Residential
Address: 1328 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	Khanh Nguyen	Failed	Thursday, February 16, 2017

Corrective Action Required

1	Misc 1	-INSTALL A LISTED REBAR GROUNDING CLAMP. THE ACORN CLAMP IS LISTED ONLY FOR GROUNDING TO GROUNDING ROD, WHICH CAN BE IN CONTACT WITH THE COPPER GROUNDING ELECTRODE CONDUCTOR.
---	--------	--

All Rough Inspection - Residential	Khanh Nguyen	Failed	Thursday, February 16, 2017
---	--------------	--------	-----------------------------

Corrective Action Required

1	Misc 1	****INSTALL EROSION CONTROL PER REQUIREMENT. NO FURTHER INSPECTION IF EC IS NOT IN COMPLIANCE -FIREBLOCK FIREPLACE SPACE FROM ROOF SPACE **STAPLE THE FIBERGLASS TO FRAMING ***DO NOT ROCK
---	--------	---

Comments: