

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20162250, Building Permit - Residential
Address: 4828 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Partial	Thursday, February 16, 2017

Corrective Action Required

1	Misc 1	-FRAME PER PLAN-CS-PF WALLS AT FRONT BED, REAR DINING, AND MASTER BED
		-HAVE ENGINEER ADDRESS FIX FOR OVER-NOTCHED JOIST ABOVE WET BAR
		**ENGINEER LETTER REQUIRED FOR THE ABOVE FIXES. ROCK AT OWN RISK

Comments: