

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20163096, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Friday, February 17, 2017

Partial Correction
1 Misc 1

OK TO COVER WHEN READY BURIED CONDUIT FOR SITE ELECTRICAL SYSTEM: TWO 1" PVC CONDUITS ACROSS NORTH DRIVEWAY APRON + TWO 1-1/2" PVC CONDUITS TO 70' WEST INTO PARKING LOT, EAST END OF WHICH IS TO BE EXTENDED/BORED EAST TO REAR OF MAIN BUILDING;

Partial Correction
2 Misc 1

OK TO POUR WHEN READY LIGHT POLE BASES: B,2; B,3; B,5;

Partial Correction
3 Misc 1

OK TO COVER WHEN READY BURIED CONDUIT TO LIGHT POLE LOCATIONS: FROM L.P. B,8 TO B,9 TO B,10; **FROM B,10 TO A,12 TO A,13;**

Comments: