

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20162554, Building Permit - Residential
Address: 1328 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection - Residential	Khanh Nguyen	Passed	Friday, February 17, 2017
All Rough Inspection - Residential	Khanh Nguyen	Passed	Friday, February 17, 2017
Electrical Service Inspection - Residential	Khanh Nguyen	Passed	Friday, February 17, 2017

Comments: