

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161179, Building Permit - Commercial
Address: 1820 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| | | | |
|--------------------------------------|------------|----------|---------------------------|
| Inspection: | Inspector: | Outcome: | Date: |
| Rated Assembly Inspection | John Borns | Partial | Friday, February 17, 2017 |

Partial Correction
1 Misc 1

OK TO TAPE, MUD AND FIRE-STOP SHOWER WALLS /CHASES AT:
1ST FLOOR UNITS;
2ND FLOOR UNITS;
3RD FLOOR UNITS: 306; 308; 309; 311; 314; 315

Partial Correction
2 Misc 1

RATED STAIRWELL WALLS:
1ST FLR: OK TO COVER UNIT-FACE AT: 106;
2ND FLR: OK TO COVER UNIT-FACE AT: 206;

Partial Correction
3 Misc 1

OK TO TAPE, MUD AND FIRE-STOP WHEN READY 5/8" TYPE X
GWB AT CEILINGS AND WALLS AT: 106; 108; 113; 114; 115; **109;**
111 INCLUDING EAST WALL ABOVE CEILING;

Comments: