

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161178, Building Permit - Commercial
Address: 1800 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Plumbing Inspection - Commercial	John Borns	Failed	Tuesday, February 21, 2017

Corrective Action Required
3 Misc 1

GREASE INTERCEPTOR SET AND PARTIALLY BACKFILLED WITH CRUSHER-RUN FINES. ANTI-BOUYANCY SLAB SAID NOT TO HAVE BEEN PLACED PER APPROVED DRAWING.

Comments: