
PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20162134, Public Works Infrastructure Permit - Commercial
HT SOLUTIONS

Address: 1440 SE BROADWAY DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
PW-Storm - Rip Rap	Brice Lawson	Passed	Tuesday, February 21, 2017

Informational

1 Brice Lawson 02/21/2017 1:47 PM

Mike's Site Work installed rip rap in the area that is located below the outlet structure. This area measures approx. 14' by 15'. Filter fabric was installed under the rip rap at this location. It appears that the rip rap that was used will work for it's intended purpose.

Comments:
