

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20160277, Building Permit - Commercial  
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Tuesday, February 21, 2017

Partial Correction  
1 Misc 1

AT ELEVATOR EQUIPMENT ROOM A150 OK TO APPLY 1ST LAYER 5/8" TYPE X GWB AT WEST WALL, 2 LAYERS AT CONNECTION WITH INTERSECTING WALL; **2ND LAYER 5/8" TYPE X GWB AT WEST WALL;**

Partial Correction  
2 Misc 1

ELEVATOR SHAFT: **LINER BOARD AT 2ND FLOOR EAST WALL;**

**Comments:**