

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161180, Building Permit - Commercial

Address: 501 NW SHAMROCK AVE, LEES SUMMIT, MO 64081521 NW SHAMROCK AVE, LEES SUMMIT,
MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	John Borns	Partial	Wednesday, February 22, 2017

Partial Correction

1 Misc 1

OK TO POUR WHEN READY GRADE BEAM CONNECTOR FROM
BLDG "B" NE TOWARD BLDG "A" PARKING GARAGE.

Partial Correction

2 Misc 1

OK TO POUR WHEN READY GRADE BEAM FROM POINT "Z" 334'
CCW TO "Y"; **FROM "Y" (EXCEPT CONSTR ACCESS) TO "X" AT
PARKING GARAGE WALL;**

GB-1'S ON 2.6 AND 3.0 FROM A.3 WEST ~15'

Partial Correction

3 Misc 1

**OK TO POUR WHEN READY ALL ISOLATED FOOTINGS EXCEPT ON
F3.0 NW OF (X);**

Comments: