

**PLANNING AND CODES ADMINISTRATION DEPARTMENT**  
**220 SE GREEN STREET**  
**LEE'S SUMMIT, MO 64063**  
**(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20162365, Building Permit - Commercial  
Address: 813 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection - Commercial</b>	John Borns	Partial	Wednesday, February 22, 2017

Partial Correction  
1 Misc 1

OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN, WASTE, & VENT PIPING.

NOTE IPC 312 / IRC P2503.5.1 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM.

<b>Underslab Electrical Inspection - Commercial</b>	John Borns	Partial	Wednesday, February 22, 2017
---	------------	---------	------------------------------

Partial Correction  
1 Misc 1

OK TO COVER WHEN READY MAIN ELECTRICAL CONDUITS FROM BUILDING ENTRY UNDER WEST EXTERIOR WALL FOOTING TO ELECTRICAL ROOM

**Comments:**