

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20152455, Building Permit - Commercial
Address: 820 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Thursday, February 23, 2017

Partial Correction

1 Misc 1

GOING FROM THE BLDG TO THE TRANSFORMER

Partial Correction

2 Misc 1

SITE ELECTRICAL TRENCHED CONDUIT: FROM PERMIT PRINT MARK (2) TO (3) TO (4) APPROX 30% COVERED BEFORE INSPECTION -- 70% APPROVED;

FROM PERMIT PRINT MARK (1) TO (1) SUBSTANTIALLY COVERED -- NOT APPROVED.

Comments: