

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20163237, Building Permit - Residential
Address: 1340 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Khanh Nguyen	Failed	Thursday, February 23, 2017

Corrective Action Required
1 Misc 1

****INSTALL EROSION CONTROL TO PROTECT THE FLOOD BASIN**

-CANNOT CUT SQUARE HOLE AND INSERT DRAIN TILE TO SUMP
PIT
-CONNECT THE DRAIN TILE WITH PROPER CONNECTOR
-PERFORATED FOUNDATION DRAIN TILES MUST BE SLEEVED
WITH FILTER MEMBRANE OR THE FILTER MEMBRANE SHALL
COVER THE GRAVEL COVERING THE DRAIN

Comments: