

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20151897, Building Permit - Commercial  
Address: 1201 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	John Borns	Passed	Thursday, February 23, 2017

**Comments: OK TO POUR WHEN READY REMAINING LIGHT POLE BASES; ONE HOLE TO BE PUMPED DRY  
IN ADVANCE OF POUR. OK TO COVER WHEN READY REMAINING TRENCHED ELECTRICAL CONDUIT.**