

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20162127, Building Permit - Residential
Address: 320 SE MILL CREEK DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mike Copeland	Failed	Thursday, February 23, 2017

Corrective Action Required

1	Misc 1	-INSTALL H CLIPS BOTH SIDES GARAGE GIRDER -MISSING SEVERAL ROOF TRUSS HANGERS. SEE LAYOUT. -H CLIPS OVER FRIDGE AND STRAP TOP PLATES -B VENT CLEARANCE IN GARAGE -2 2x12 HEADER OVER GARAGE IS OVERSPAN. -BEAM BEARING ON CONCRETE NEEDS BEARING THE FULL WIDTH. -PROVIDE LADDER TO INSPECT COVERED PORCH FRAMING. -FIND UFFER GROUND
---	--------	--

Electrical Service Inspection - Residential	Mike Copeland	Failed	Thursday, February 23, 2017
--	---------------	--------	-----------------------------

Corrective Action Required

1	Misc 1	NO UFFER GROUND INSTALLED
---	--------	---------------------------

Gas Piping Inspection - Residential	Mike Copeland	Passed	Thursday, February 23, 2017
--	---------------	--------	-----------------------------

Gas Service Inspection - Residential	Mike Copeland	Passed	Thursday, February 23, 2017
---	---------------	--------	-----------------------------

Comments: