

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20162365, Building Permit - Commercial
Address: 813 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	John Borns	Partial	Friday, February 24, 2017

Partial Correction
1 Misc 1

OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN, WASTE, & VENT PIPING.

NOTE IPC 312 / IRC P2503.5.1 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM.

Partial Correction
2 Misc 1

OK TO COVER WHEN READY RADON COLLECTION PIPING SYSTEM FOUND INSTALLED SUBSTANTIALLY PER REVISION /10N DRAWING SHEET 2.00. ROOF DRAIN PIPING IN PLACE TO BUILDING EXIT.

Underslab Electrical Inspection - Commercial	John Borns	Partial	Friday, February 24, 2017
---	------------	---------	---------------------------

Partial Correction
1 Misc 1

OK TO COVER WHEN READY ELECTRICAL CONDUITS FROM BUILDING ENTRIES UNDER WEST AND EAST EXTERIOR WALL FOOTINGS TO ELECTRICAL ROOM.

Comments: