

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20162591, Building Permit - Residential
Address: 1805 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Residential	John Borns	Passed	Friday, February 24, 2017

**Comments: SIDE SETBACK IS >3' SINCE FENCE IS STATED TO BE 1'+ INSIDE PROPEERTY LINE. NO ISSUES.
CLOSE PERMIT.**