

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20151897, Building Permit - Commercial
Address: 1201 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Monday, February 27, 2017

Partial Correction
2 Misc 1

ELEVATOR SHAFT
4 LAYERS (W/ REILIENT CHANNEL) 5/8" TYPE X GWB AT LID
TWO LAYERS 5/8" TYPE X GWB AT N,E,S WALLS COMPLETE,
TAPED, AND MUDDED

Partial Correction
3 Misc 1

OK TO COVER AT STAIRWELLS: 2 LAYERS 5/8" TYPE X GWB AT
WALLS BOTH STAIRWELLS; RESILIENT FURRING + 5/8" TYPE X
GWB AT LANDING CEILINGS

Partial Correction
4 Misc 1

OK TO TAPE, MUD, AND FIRE-STOP WHEN READY RATED WALLS
AND CEILINGS AT: 4TH FLOOR; 3RD FLOOR INCLUDING
ELECTRICAL ROOM & BACK OF HOUSE; 2ND FLOOR INCLUDING
ELECTRICAL ROOM; CORRIDORS, ELEVATOR LOBBY;
1ST FLOOR: 116; **101; 103; 105; 107; 109; 111; 113; 106 W WALL**
1ST LAYER;

Partial Correction
5 Misc 1

LAUNDRY CHUTE: OK TO COVER WHEN READY: 1ST LAYER 5/8"
TYPE X GWB;

Comments: