

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160277, Building Permit - Commercial
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Monday, February 27, 2017
Partial Correction 1 Misc 1		OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING LOCATIONS: 1ST FLOOR: EAST WALL OF ELECT 3-161; OK TO 4' TOP-OUT WALLS; AREA "A"; AREA "C" COMPLETE EXCEPT C160; B153; D161; 2ND FLOOR: AREA "A"; AREA "C" N OF STAIR;	
Partial Correction 2 Misc 1		OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING 2ND FLOOR LOCATIONS: A218; C271;	
Rated Assembly Inspection	John Borns	Partial	Monday, February 27, 2017
Partial Correction 1 Misc 1		AT ELEVATOR EQUIPMENT ROOM A150 OK TO APPLY 1ST LAYER 5/8" TYPE X GWB AT WEST WALL, 2 LAYERS AT CONNECTION WITH INTERSECTING WALL; 2ND LAYER 5/8" TYPE X GWB AT WEST WALL (GWB AT TOP OF WALL NOT FASTENED TIGHT AT WF BEAM);	
Partial Correction 2 Misc 1		ELEVATOR SHAFT: OK TO COVER LINER BOARD AT 2ND FLOOR EAST WALL;	

Comments:

