



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20161177	Date:	February 28, 2017
Project Title:	JOHN KNOX VILLAGE - MEADOWS	Applicant:	
Location:	500 NW MOORE ST, LEES SUMMIT, MO 64081	NATIONAL FIRE SUPPRESSION	501 SUNSHINE RD KANSAS CITY, KS 66115
Type of Work:		Primary:	(913) 321-9208
Occupancy Group:	R-2		
Description:	BUILDING C -NEW 3 STORY INDEPENDENT LIVING UNIT		
Construction Type:	Type VA (1 hour)		
Map Page:	194D		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test. FIELD TESTING AND ACCEPTANCE TESTING WILL BE REQUIRED FOR THE SYSTEM PRIOR TO THE FINAL OCCUPANCY INSPECTION. TO SCHEDULE A TEST CONTACT THE FIRE DEPARTMENT AT 816-969-1300.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.