## PLANNING AND CODES ADMINISTRATION DEPARTMENT 220 SE GREEN STREET LEE'S SUMMIT, MO 64063 (816) 969-1200 FAX (816) 969-1201

## **Inspection Summary**

Permit #:PRCOM20161058, Building Permit - Commercial Address: 1200 SE HAMBLEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Underground Electrical Mike Copeland Partial Tuesday, February 28, 2017

Inspection - Commercial

**Partial Correction** 

1 Misc 1 LIGHT POLE BASES APPROVED

DUCT BANK TO GENERATOR PAD 60 FEET APPROVED

**Partial Correction** 

2 THE FOLLOWING AREAS NO ISSUES FOUND ON TRENCHED PVC ELECTRICAL CONDUIT:

ARE APPROVED FROM GENERATOR LOCATION: ONE 1" N/NE TO L.P. AT N EDGE OF DETENTION POND; ONE 2" + THREE 1' NE TO J.B. @ GATE

CONTROLLER; FIVE 1" NW TO FUEL PUMP LOCATION

**Partial Correction** 

3 THE FOLLOWING AREAS -PRIMARY CONDUITS FROM TRANSFORMER PAD TO BUILDING

ARE APPROVED APPROVED

-NORTH PARKING LIGHTING APPROVED -SOUTH PARKING LIGHTING APPROVED -WEST PARKING LIGHTING APPROVED

-DUCT BANK FROM HARDENED ROOM TO WEST LOCATION

**APPROVED** 

**Partial Correction** 

4 Misc 1 CONDUITS FOR EXTERIOR RECEPTACLES AT SOUTH COLUMNS

APPROVED.

Underslab Electrical Mike Copeland Partial Tuesday, February 28, 2017

Inspection - Commercial

**Partial Correction** 

## 1 THE FOLLOWING AREAS ARE APPROVED

-COUNDUITS NORTH SIDE OF THE HARDENED ROOM, TO UTILITY ROOM AND THROUGH NORTH SIDE OF AREA B THROUGH FOOTING.

-AREA A AND B, CONDUITS FOR FLOOR BOXES AND HOMERUNS APPROVED

-AREA B GROUNDING ELETRODE CONUCTORS GOING TO NORTH AND SOUTH GROUD RINGS APROVED AND CONDUITS IN AREA BE AND HARDENED ROOM APPROVED.

-AREA C AND AREA D APPROVED

## **Comments:**