

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20162583, Building Permit - Commercial
Address: 20 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Tuesday, February 28, 2017
Partial Correction 1 Misc 1		OK TO COVER WHEN READY ACT CEILING FRAMING + ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES: 1C216; 1C133; C137; [1D25]; 1C217; 1C218A; 1C219; 1C221; 1C223; 1C218 INCLUDING EAST 1/2; 1D24; 1D26 AFTER RATED WALL STICKERS ARE ADHERED TO WALL RATHER THAN TO M/E/P COMPONENTS; 1C117-1C120; 1C101; 1D25; 1D26; 1C1122; 1C123; FACIA ONLY AT SOFFIT IN 1C116; PARTIAL FOR MODIFICATIONS AT IR READ ROOM 116;	
Partial Correction 2 Misc 1		OK TO COVER WHEN READY LIGHT-GAUGE STEEL FRAMING FOR SOFFITS ABOVE DOORS AT TWO PREP ROOMS	
In-wall Inspection	John Borns	Partial	Tuesday, February 28, 2017
Partial Correction 1 Misc 1		OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING LOCATIONS: 1C122 SOUTH WALL; 1C216; 1C217; CUT-IN DOOR 1C219; 1D23 NW WALL B/F; 1D25; 1D26; IN-FILL AT 1D22 N WALL B/F; 1D24 B/F; 1D25 O/SF; 1D26 W WALL B/F; 1D221 E WALL B/F; 1C223; 1C221 CONTINGENT ON SEGMENT OF CORRIDOR SMOKE WALL BEING SMOKE-SEALED; C137; E/NE WALL; 1C120 & 121 B/F; 1C218 E & S WALLS; [1C118] E & NW; [1C120] S WALL; [1C218] N WALL AFTER 2 BOCA PLATES IN PLACE; WALL AT/ADJACENT TO DOOR (1D23); [1C118] W WALL; [1C118A] E WALL; [1C119] S WALL; CHASE AT [218] SE CORNER; [1C219] E & W WALLS; WING WALL @ [1C219]	

S; N WALL OF NEWLY-ENCLOSED CLOSET PER PR#5 AT [1D23]
SOUTH; [1C211] N WALL B/F; FRAMING AT DOOR OPENINGS
(1C101) & (1C197) B/F; [1C101]; SINK MODIFICATION AT 1C123;
TWO CHASES/ COLUMN WRAPS IN 1C116;

B/F = BOTH FACES
O/SF = OUTSIDE FACE

**Final Building
Inspection -
Commercial**

John Borns

Partial

Tuesday, February 28, 2017

Partial Correction

1 Misc 1

SPACES OK FOR USE: 1D22 EKG/VASCULAR; 1C133; 1C216; 1C137;
1C101; 1C117-1C120 BLOOD DRAW AREA; 1C124; 1C125; 1C218 ;
1C218A; 1C219; 1C221; 1C223;

Comments: