

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161179, Building Permit - Commercial  
Address: 1820 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Commercial</b>	John Borns	Partial	Wednesday, March 01, 2017

Partial Correction  
1

**RELEASE TEMPORARY ELECTRICAL SERVICE**

<b>Rated Assembly Inspection</b>	John Borns	Not Ready	Wednesday, March 01, 2017
--------------------------------------	------------	-----------	---------------------------

Partial Correction  
1      Misc 1

**RATED STAIRWELL WALLS:**  
1ST FLR: OK TO COVER UNIT-FACE AT: 106;  
2ND FLR: OK TO COVER UNIT-FACE AT: 206;

**WEST STAIRWELL, STAIRWELL FACE NOT APPROVED: INSTALL  
ASW CLIPS PER MANUFACTURER'S INSTRUCTIONS. NO  
LEVEL-TO-LEVEL FIREBLOCKING INSTALLED.**

Partial Correction  
2      Misc 1

OK TO TAPE, MUD AND FIRE-STOP WHEN READY 5/8" TYPE X  
GWB AT 1ST FLOOR CEILINGS AND WALLS AT 1ST FLOOR: 106;  
108; 113; 114; 115; 109; 111 INCLUDING EAST WALL ABOVE  
CEILING;

Partial Correction  
3      Misc 1

OK TO TAPE, MUD AND FIRE-STOP WHEN READY 5/8" TYPE X  
GWB AT 2ND FLOOR CEILINGS AND WALLS AT: CORRIDOR; 206;  
208; 213; 214; 215;

Partial Correction  
4      Misc 1

OK TO TAPE, MUD AND FIRE-STOP WHEN READY 5/8" TYPE X  
GWB AT 3RD FLOOR CEILINGS AND WALLS AT: CORRIDOR; 306;

308; 309; 311; 313; 314;

**All Rough Inspection -** John Borns  
**Commercial**

Partial

Wednesday, March 01, 2017

Partial Correction

1 Misc 1

OK TO COVER WHEN READY  
WALL FRAMING, CEILING  
FRAMING AND CONCEALED  
SYSTEMS AT 1ST FLOOR SPACES:  
104; 106; 108; 109; 111; 113;  
114; 115; MAIN  
CORRIDOR/VESTIBULE; 102; **103;**  
**110; 116&117 EXCEPT**  
**CLEANOUT ACCESS AT**  
**PLUMBING STACK;**

Partial Correction

2 Misc 1

OK TO COVER WHEN READY WALL FRAMING, CEILING FRAMING  
AND CONCEALED SYSTEMS AT 2ND FLOOR SPACES: 206; 208; 209  
BA & CLO CLGS ONLY; 211; 213; 214; 215; JOIST SPACE ABOVE  
CORRIDOR AND ELEVATOR VESTIBULE; 209; 211; 202; 203; 204 N,  
E, S WALLS; **210**

Partial Correction

3 Misc 1

OK TO COVER WHEN READY WALL FRAMING, CEILING FRAMING  
AND CONCEALED SYSTEMS AT 3RD FLOOR SPACES: SHOWER  
WALLS /CHASES; CORRIDOR; **ALL UNITS INCLUDING 315**

**Comments:**