

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20162474, Building Permit - Commercial
Address: 415 SW JEFFERSON ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Partial	Wednesday, March 01, 2017

Partial Correction
1 Misc 1

NO ISSUES FOUND ON: INSTALLATION OF TRIPLE 2x10 CENTER BEAM, JOISTS AND 6x6 POSTS AT BASEMENT; RESTROOM WALL, WINDOW AND DOOR FRAMING AT UPPER LEVEL; 2x4 STUDS ADDED TO SOUTH KNEE WALL FRAMING AT ATTIC; W4x13 HEADER OVER WEST ENTRANCE DOOR; SIX 6x6 WOOD COLUMNS AT BASEMENT; 1ST FLOOR INTERIOR WALL STRAP BRACING COMPLETE PER DRAWING; SUBFLOOR PATCHES AT HVAC OVER-CUTS; **TWO 2x8 HEADERS INSTALLED TO SUPPORT LOADS ABOVE AT EAST END OF 1ST FLOOR**

Comments: