

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20152455, Building Permit - Commercial
Address: 820 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	John Borns	Partial	Wednesday, March 01, 2017

Partial Correction
1 Misc 1

SCOPE OF DEVELOPMENT AGREEMENT + PERMIT (BUILDING + SITE) IS NOT COMPLETED FOR FULL FINAL INSPECTION. HOWEVER, NO REASON FOUND WHY WORK SHOULD NOT PROCEED ON INTERIOR FINISH FOR H&M.

SOME EXTERIOR SIDELIGHT UNITS MAY NOT BE APPROVABLE RE SAFETY GLAZING.
PAPER-FACED INSULATION MAY NOT BE LEFT EXPOSED.
REQUEST FULL FINAL INSPECTION WHEN WORK IS COMPLETED.

Comments: