

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20162246, Building Permit - Residential
Address: 1333 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	Khanh Nguyen	Passed	Thursday, March 02, 2017

All Rough Inspection - Residential	Khanh Nguyen	Failed	Thursday, March 02, 2017
---	--------------	--------	--------------------------

Corrective Action Required

1 Misc 1

-STRAP GARAGE PORTAL BRACE WALLS
**THIS IS NOT HOW TO STRAP THE GARAGE PORTAL WALLS.
FRAMER PLEASE LOOK AT THE DETAIL PAGE ON THE PLAN.

-FIREBLOCK DUCT AND PLUMBING SPACES AT PANTRY/MUD AND
HALF BATH
**FB THESE SPACES FROM CEILING FURDOWN SPACE

***ACCESS TO UFER GROUNDING CONNECTION AT FINAL
***OK TO INSULATE

Comments: