

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20162366, Building Permit - Commercial
Address: 825 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	John Borns	Partial	Thursday, March 02, 2017

Partial Correction			
1	Misc 1	OK TO POUR WHEN READY BUILDING PERIMETER FOOTING	
Partial Correction			
2	Misc 1	OK TO POUR WHEN READY ELEVATOR PIT SLAB	
Partial Correction			
3	Misc 1	OK TO POUR WHEN READY GARAGE PERIMETER FOOTING	

Underslab Electrical Inspection - Commercial	John Borns	Passed	Thursday, March 02, 2017
---	------------	--------	--------------------------

Underslab Plumbing Inspection - Commercial	John Borns	Partial	Thursday, March 02, 2017
---	------------	---------	--------------------------

Partial Correction			
1	Misc 1	OK TO COVER WHEN READY: UNDER-SLAB PVC SANITARY DRAIN, WASTE, & VENT PIPING.	
		UNDER-SLAB ROOF DRAIN PIPING TO BUILDING EXIT AT NORTH PERIMETER FOOTING.	
		NOTE IPC 312 / IRC P2503.5.1 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM.	

**RADON COLLECTION PIPING SYSTEM FOUND INSTALLED
SUBSTANTIALLY PER REVISION /1\ ON DRAWING SHEET 2.00.**

Comments: