

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20162365, Building Permit - Commercial
Address: 813 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------|----------|--------------------------|
| Foundation Inspection - Commercial | John Borns | Partial | Thursday, March 02, 2017 |

Partial Correction
1 Misc 1

ELEVATOR PIT WALLS: EAST WALL HANGS OVER EDGE OF SLAB;
EDGE OF SLAB HAS BEEN DOWELED. CONDITION ALLOWED THIS
INSTANCE ONLY AS EXCEPTION TO DRAWINGS.

Partial Correction
2 Misc 1

**OK TO POUR POST-TENSIONED BUILDING FLOOR SLAB SYSTEM
AS APPROVED BY SPECIAL INSPECTOR. ENSURE UFER GROUND
LEADS REMAIN EXTENDED OUTSIDE POUR.**

Partial Correction
3 Misc 1

**OK TO POUR POST-TENSIONED GARAGE FLOOR SLAB SYSTEM AS
APPROVED BY SPECIAL INSPECTOR.**

Comments: