

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161758, Building Permit - Commercial
Address: 789 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Thursday, March 02, 2017

Partial Correction
1 Misc 1

DATA COMM CONDUIT NETWORK TO BUILDINGS:
QUAZITE BOX (A) SET IN PLACE
TWO 4" + TWO 1-1/4" PVC + 2" ROLLPIPE...
FROM QUAZITE BOX (A) TO BLDG #1; TO BLDG #2; TO
CLUBHOUSE; NORTH TO 50' N OF FIRE HYDRANT; N TO Q-BOX
LOCATION #3; N TO MARK (2.6); N/NW TO Q-BOX LOCATION #2);
BETWEEN BLDGS #3 & 34;

Comments: