

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20151897, Building Permit - Commercial  
Address: 1201 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Thursday, March 02, 2017

Partial Correction  
1 Misc 1

ELEVATOR SHAFT  
4 LAYERS (W/ REILIENT CHANNEL) 5/8" TYPE X GWB AT LID  
TWO LAYERS 5/8" TYPE X GWB AT N,E,S WALLS COMPLETE,  
TAPED, AND MUDDED

Partial Correction  
2 Misc 1

OK TO COVER AT STAIRWELLS: 2 LAYERS 5/8" TYPE X GWB AT  
WALLS BOTH STAIRWELLS; RESILIENT FURRING + 5/8" TYPE X  
GWB AT LANDING CEILINGS

Partial Correction  
3 Misc 1

OK TO TAPE, MUD, AND FIRE-STOP WHEN READY RATED WALLS  
AND CEILINGS AT: 4TH FLOOR; 3RD FLOOR; 2ND FLOOR;  
1ST FLOOR: 116; 101; 103; 105; 107; 109; 111; 113; 106 W WALL  
1ST LAYER; **MEETING ROOM; POOL (2ND LAYER AT W WALL);**

Partial Correction  
4 Misc 1

LAUNDRY CHUTE: OK TO COVER WHEN READY: 1ST LAYER 5/8"  
TYPE X GWB;

**Comments:**