

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20152455, Building Permit - Commercial
Address: 820 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Thursday, March 02, 2017

Partial Correction

1 Misc 1

SITE ELECTRICAL TRENCHED CONDUIT: FROM PERMIT PRINT MARK (2) TO (3) TO (4) APPROX 30% COVERED BEFORE INSPECTION -- 70% APPROVED; WITHIN 20' OF/AT J.B. AT (9); FROM (3) TO (10); FROM (10) TO (11); FROM (4) TO (8); FROM (5) TO (6) TO (7) TO (9);

FROM PERMIT PRINT MARK (1) TO (2) SUBSTANTIALLY COVERED -- NOT APPROVED.

Corrective Action Required

2 Misc 1

OK TO POUR WHEN READY LIGHT POLE BASES AT PRINT MARKS: #1; 2; 4; 9;

Comments: