

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160836, Building Permit - Commercial
Address: 2641 NE MCBAINE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mike Copeland	Failed	Thursday, March 02, 2017

Corrective Action Required

1	Misc 1	-FIRESTOP PENETRATIONS IN TOP PLATE TO ATTIC AREA. -FIREBLOCK AT FIREPLACE AND SOUTH EAST BATH DOUBLE WALL. -INSTALL STRUCTURAL STRAPS AT EXTERIOR WALLS WHERE 50% OF THE TOP PLATES HAVE BEEN DRILLED OR NOTCHED. -INSTALL PLUMBING PROTECTION AT TOP AND BOTTOM PLATES. OKAY TO ROCK THE LIDS OF THE HALLWAYS AND ONE SIDE OF THE HALLWAYS
---	--------	--

Gas Service Inspection - Commercial	Mike Copeland	Passed	Thursday, March 02, 2017
--	---------------	--------	--------------------------

Gas Piping Inspection - Commercial	Mike Copeland	Passed	Thursday, March 02, 2017
---	---------------	--------	--------------------------

Comments: