

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20162811, Building Permit - Commercial
Address: 860 NW BLUE PKWY, Unit:W, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Friday, March 03, 2017

Partial Correction
1 Misc 1

NEW DOOR 120B -- OK TO COVER WHEN READY: WALL FRAMING AND SOUTH FACE 1ST LAYER 5/8" TYPE X GWB; NORTH FACE 1ST LAYER 5/8" TYPE X GWB; THEN OK TO TAPES, MUD AND FIRE-STOP AS NECESSARY TWO LAYERS AT BOTH FACES.

Comments: