

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161180, Building Permit - Commercial

Address: 501 NW SHAMROCK AVE, LEES SUMMIT, MO 64081521 NW SHAMROCK AVE, LEES SUMMIT,
MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Electrical Inspection - Commercial	John Borns	Passed	Friday, March 03, 2017
Suspended Slab Inspection	John Borns	Passed	Friday, March 03, 2017

Comments: NO MATERIAL OR WORKMANSHIP ISSUES FOUND WITH ELECTRICAL CONDUIT AND BOXES TO BE CAST INTO POUR OF POST-TENSIONED CONCRETE SLAB AT PARKING GARAGE. SLAB OK FOR CONCRETE PLACEMENT WHEN APPROVED BY SPECIAL INSPECTOR.