

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161179, Building Permit - Commercial
Address: 1820 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Friday, March 03, 2017

Partial Correction
1 Misc 1

RATED STAIRWELL WALLS -- OK TO COVER:
1ST FLR: UNIT-FACE AT: 106;
2ND FLR: UNIT-FACE AT: 206;

WEST AND EAST STAIRWELLS AT STAIRWELL FACE

Partial Correction
2 Misc 1

OK TO TAPE, MUD AND FIRE-STOP WHEN READY 5/8" TYPE X
GWB AT 1ST FLOOR CEILINGS AND WALLS AT: 106; 108; 113; 114;
115; 109; 111 INCLUDING EAST WALL ABOVE CEILING; **MAIN CORRIDOR;**

Partial Correction
3 Misc 1

OK TO TAPE, MUD AND FIRE-STOP WHEN READY 5/8" TYPE X
GWB AT 2ND FLOOR CEILINGS AND WALLS AT: CORRIDOR; 206;
208; 213; 214; 215; **209; 211;**

Partial Correction
4 Misc 1

OK TO TAPE, MUD AND FIRE-STOP WHEN READY 5/8" TYPE X
GWB AT 3RD FLOOR CEILINGS AND WALLS AT: CORRIDOR; 306;
308; 309; 311; 313; 314; **315;**

All Rough Inspection - Commercial	John Borns	Partial	Friday, March 03, 2017
--	------------	---------	------------------------

Partial Correction
1 Misc 1

OK TO COVER WHEN READY WALL FRAMING, CEILING FRAMING
AND CONCEALED SYSTEMS AT 1ST FLOOR SPACES: 104; 106; 108;
109; 111; 113; 114; 115; MAIN CORRIDOR/VESTIBULE; 102; 103;

Partial Correction
2 Misc 1

110; 116&117 EXCEPT CLEANOUT ACCESS AT PLUMBING STACK;

OK TO COVER WHEN READY WALL FRAMING, CEILING FRAMING AND CONCEALED SYSTEMS AT 2ND FLOOR SPACES: 206; 208; 209 BA & CLO CLGS ONLY; 211; 213; 214; 215; JOIST SPACE ABOVE CORRIDOR AND ELEVATOR VESTIBULE; 209; 211; 202; 203; 204 N, E, S WALLS; 210; **216; 217;**

Partial Correction
3 Misc 1

OK TO COVER WHEN READY WALL FRAMING, CEILING FRAMING AND CONCEALED SYSTEMS AT 3RD FLOOR SPACES: SHOWER WALLS /CHASES; CORRIDOR; ALL UNITS INCLUDING 315; **302; 303; 304; 316; 317;**

Partial Correction
4 Misc 1

OK TO COVER WHEN READY 1ST FLOOR GWB DROP CEILING AREAS AT:
BATHROOMS AT 109; 111;

Partial Correction
5 Misc 1

OK TO COVER WHEN READY 2ND FLOOR GWB DROP CEILING AREAS AT:

Partial Correction
6 Misc 1

OK TO COVER WHEN READY 3RD FLOOR GWB DROP CEILING AREAS AT:

Comments: