



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No: PRCOM20170298 Date: March 06, 2017
Project Title: MIDWEST PAIN MANAGEMENT Applicant:
CENTER - PRIVACY PARTITIONS
Location: JAYHAWK FIRE SPRINKLER CO INC
200 NE MISSOURI RD, Unit:100, PO BOX 8458
LEES SUMMIT, MO 64086 TOPEKA, KS 66608
Type of Work: Primary: (913) 422-3770
Occupancy Group:
Description: CONSTRUCTION OF PRIVACY
PARTITIONS IN EXISTING PRE-OP
AREA
Construction Type: Type IIB (Unprotected)
Map Page: 175Y

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.
THE EXISITING FIRE SPRINKLER SYSTEM SHALL BE CURRENT WITH ALL REQUIRED SERVICE AND MAINTENANCE. A CURRENT SERVICE TAG SHALL BE POSTED ON THE SYSTEMS RISER.
(VERIFIED AT INSPECTION)

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.