

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20162367, Building Permit - Commercial
Address: 819 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Mike Copeland	Passed	Monday, March 06, 2017

Partial Correction
1 Misc 1

AFTER UFER GROUND JUMPERS ARE IN PLACE OK TO POUR
WHEN READY PERIMETER FOOTING AT N,E,S.

Partial Correction
2 Misc 1

OK TO POUR WHEN READY ELEVATOR PIT SLAB

Partial Correction
3 Misc 1

OK TO POUR POST-TENSIONED FLOOR SLAB SYSTEM AS
APPROVED BY SPECIAL INSPECTOR. ENSURE OPENINGS IN VAPOR
BARRIER ARE SEALED.

Comments: