

FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No: PRCOM20161178 Project Title: JOHN KNOX VILLAGE -MEADOWS Date: March 07, 2017 Applicant:

Location: 1800 NW OBRIEN RD, LEES SUMMIT, MO 64081

Type of Work:Occupancy Group:A-2Description:COMMONS BUILDINGConstruction Type:Type VA (1 hour)Map Page:194D

PARIC CORPORATION 120 S CENTRAL AVE STE 400 CLAYTON, MO 63105

PARIC CORPORATION 120 S CENTRAL AVE STE 400 CLAYTON, MO 63105

Primary: (636) 561-9500

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Joe Dir

Rejected

1. Origianl fire alarm plans (not alterations) shall come bearing a PE stamp.

2. Check all stairways throughout all buildings all floors to assure there are no strobe notification devices located within the stairways.

3. Check all corridor fire doors throughout all buildings and all floors to assure there is a smoke detector on each side of the doors.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.