

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20170293, Building Permit - Residential
Address: 3603 SW CRANE RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Mark Harding Residential		Failed	Tuesday, March 07, 2017

Corrective Action Required

1	Misc 1	Interior inspected need to install pressure gauge on exterior 1`0lbs for 15min and recall for inspection.
---	--------	---

Comments: