

Inspection Summary

Permit #: PRCOM20152455, Building Permit - Commercial
Address: 820 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	Mike Copeland	Partial	Tuesday, March 07, 2017
Partial Correction 1 Misc 1	SCOPE OF DEVELOPMENT AGREEMENT + PERMIT (BUILDING + SITE) IS NOT COMPLETED FOR FULL FINAL INSPECTION. HOWEVER, NO REASON FOUND WHY WORK SHOULD NOT PROCEED ON INTERIOR FINISH FOR H&M. SOME EXTERIOR SIDELIGHT UNITS MAY NOT BE APPROVABLE RE SAFETY GLAZING. PAPER-FACED INSULATION MAY NOT BE LEFT EXPOSED. REQUEST FULL FINAL INSPECTION WHEN WORK IS COMPLETED.		
Corrective Action Required 2 Misc 1	SUBMIT SPECIAL INSPECTION APPROVAL DOCUMENTATION. OKAY TO PROCEED WITH TENANT PERMITS.		

Comments: