

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160277, Building Permit - Commercial

Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mark Harding	Partial	Tuesday, March 07, 2017

Partial Correction

1 Misc 1

AT ELEVATOR EQUIPMENT ROOM A150 OK TO APPLY 1ST LAYER 5/8" TYPE X GWB AT WEST WALL, 2 LAYERS AT CONNECTION WITH INTERSECTING WALL; 2ND LAYER 5/8" TYPE X GWB AT WEST WALL; FRAMING + ONE LAYER 1" LINER BOARD AT CEILING; SOUTH WALL OK TO COVER SOUTH FACE OF SOUTH WALL WITH 5/8" TYPE X; OK TO COVER SOUTH FACE OF SOUTH WALL WITH 2ND LAYER 5/8" TYPE X; OK TO INSTALL 2ST LAYER 5/8" TYPE X GWB AT CEILING;

::NORTH, SOUTH, EAST WALLS 1ST 2ND FLOOR ELEVATOR, ELEVATOR EQUIPMENT ROOM CEILING 2ND LAYER.

Partial Correction

2 Misc 1

ELEVATOR SHAFT -- OK TO COVER WHEN READY: FRAMING + LINER BOARD FULL HEIGHT NORTH, EAST, SOUTH WALLS; EAST WALL 2ND FLOOR 1ST LAYER 5/8" TYPE X; 2ND FLOOR OK FOR 2ND LAYER 5/8" TYPE X AT N,E,S WALLS; 1ST FLOOR N WALL OK TO HANG BOTH LAYERS 5/8" TYPE X GWB;

Partial Correction

3 Misc 1

2ND FLOOR SEPARATION WALL ON (6) FROM (N) TO (Q) WEST FACE 1ST LAYER 5/8" TYPE X GWB OK FOR 2ND LAYER;

Comments: