

**PLANNING AND CODES ADMINISTRATION DEPARTMENT**  
**220 SE GREEN STREET**  
**LEE'S SUMMIT, MO 64063**  
**(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20162811, Building Permit - Commercial  
Address: 860 NW BLUE PKWY, Unit:W, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Mike Copeland	Partial	Tuesday, March 07, 2017

Partial Correction  
1 Misc 1

1st LAYER OF SPRAY FIRE RESISTIVE PAINT APPLIED TO DECK JOISTS.  
APPLY TO NON TREATED WOOD IN PARTITION NON BEARING WALLS.

**Comments:**