

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161179, Building Permit - Commercial  
Address: 1820 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Mark Harding	Partial	Wednesday, March 08, 2017

Partial Correction  
1 Misc 1

RATED STAIRWELL WALLS -- OK TO COVER:  
1ST FLR: UNIT-FACE AT: 106; 102-4 116-7  
2ND FLR: UNIT-FACE AT: 206;

WEST AND EAST STAIRWELLS AT STAIRWELL FACE

Partial Correction  
2 Misc 1

OK TO TAPE, MUD AND FIRE-STOP WHEN READY 5/8" TYPE X  
GWB AT 1ST FLOOR CEILINGS AND WALLS AT: 106; 108; 113;  
114; 115; 109; 111 INCLUDING EAST WALL ABOVE CEILING; MAIN  
CORRIDOR; 102-4 116-7

Partial Correction  
3 Misc 1

OK TO TAPE, MUD AND FIRE-STOP WHEN READY 5/8" TYPE X  
GWB AT 2ND FLOOR CEILINGS AND WALLS AT: CORRIDOR; 206;  
208; 213; 214; 215; 209; 211; 202-4 216-7

Partial Correction  
4 Misc 1

OK TO TAPE, MUD AND FIRE-STOP WHEN READY 5/8" TYPE X  
GWB AT 3RD FLOOR CEILINGS AND WALLS AT: CORRIDOR; 306;  
308; 309; 311; 313; 314; 315;  
302-4 316-7

**Comments:**