

CODES ADMINISTRATION

PLAN REVIEW CONDITIONS

March 09, 2017

DIAMOND CONTRACTORS INC
4224 NE PORT DR
LEES SUMMIT, MO 64064

Permit No: PRCOM20170501
Project Title: BRAIN BALANCE LEE'S SUMMIT
Project Address: 413 NW MURRAY RD, LEES SUMMIT, MO 64081
Parcel Number: 62110051500000000
Location: J.K.V. EAST COMMERCIAL DEVELOPMENT---LOT 3
Type of Work: NEW TENANT FINISH
Occupancy Group:
Description: COMMERCIAL TENANT FINISH

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Joe Frogge

Approved

Fire Plan Review

Reviewed By: Jim Eden

Approved with Conditions

1. NO KEYED LOCKS ON THE EGRESS SIDE ON A MARKED EXIT. (VERIFIED AT INSPECTION)

2. 2012 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. .A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions. HAVE THE FIRE ALARM SYSTEM CONTRACTOR PROVIDE SHOP DRAWINGS FOR ANY MODIFICATIONS TO BE DONE TO THE FIRE ALARM SYSTEM. (INFORMATION PURPOSES)

3. 2012 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm). POST THE NUMERIC ADDRESS OF 413 ON THE EXTERIOR OF THE FRONT AND REAR DOORS. THE ADDRESS SHALL BE IN A CONTRASTING COLOR TO THE BACKGROUND. ADDRESS SHALL BE READBLE FROM THE ROADWAY. (VERIFIED AT INSPECTION)

4. 2012 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

PROVIDE A MINIMUM OF ONE 2A-10BC FIRE EXTINGUISHER. (5 POUND) ONE FOR EVERY 3,000 SQ FT OF BUSINESS SPACE.
(VERIFIED AT INSPECTION)

5. 2012 IFC 906.5- Conspicuous location. Portable fire extinguishers shall be located in conspicuous locations where they will be readily accessible and immediately available for use. These locations shall be along normal paths of travel, unless the fire code official determines that the hazard posed indicates the need for placement away from normal paths of travel.
MOUNT THE FIRE EXTINGUISHER TO HAVE A MAXIMUM TRAVEL DISTANCE OF 75 FEET FROM ANYWHERE WITHIN THE BUSINESS AREA.

6. 2012 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

HAVE THE FIRE SPRINKLER CONTRACTOR PROVIDE SHOP DRAWINGS OF ANY MODIFICATIONS TO BE DONE TO THE FIRE SPRINKLER SYSTEM.

(INFORMATION PURPOSES)

7. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ANY MODIFICATION DONE TO THE FIRE ALARM SYSTEM SHALL BE TESTED PRIOR TO THE FINAL OCCUPANCY INSPECTION.

(INFORMATION PURPOSES)

Licensed Contractors

Reviewed By: Joe Frogge

Approved

- ☒ Approved to issue per the listed conditions.
☐ Do not issue per the listed conditions.
☐ Approved to construct foundation only per the listed conditions.
☐ Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

Signature of Applicant

Date

Print Applicant Name

CompanyName

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.