

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20162973, Building Permit - Residential

Address: 2113 SW TIMBERTRACE LN, LEES SUMMIT, MO 640822115 SW TIMBERTRACE LN, LEES
SUMMIT, MO 640822117 SW TIMBERTRACE LN, LEES SUMMIT, MO 640822111 SW
TIMBERTRACE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection - Residential	Mark Harding	Partial	Thursday, March 09, 2017
Erosion Control	Mark Harding	Failed	Thursday, March 09, 2017

Comments: