

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20151897, Building Permit - Commercial
Address: 1201 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Mike Copeland	Partial	Thursday, March 09, 2017

Partial Correction
1 Misc 1

OK TO COVER WHEN READY SYSTEMS ABOVE LOWER GWB
CEILINGS AT: 4TH FLOOR; 3RD FLOOR; 2ND FLOOR EXCEPT
ELEVATOR LOBBY AND BACK OF HOUSE;

Partial Correction
2 Misc 1

LOBBY AND MEETING ROOMS 1ST FLOOR, CHANNEL INSTALLED
16" O.C. AND FIRECAULK PENETRATIONS APPROVED TO COVER.

Comments: