

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160277, Building Permit - Commercial
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mike Copeland	Partial	Thursday, March 09, 2017

Partial Correction
1 Misc 1

AT ELEVATOR EQUIPMENT ROOM A150 OK TO APPLY 1ST LAYER 5/8" TYPE X GWB AT WEST WALL, 2 LAYERS AT CONNECTION WITH INTERSECTING WALL; 2ND LAYER 5/8" TYPE X GWB AT WEST WALL; FRAMING + ONE LAYER 1" LINER BOARD AT CEILING; SOUTH WALL OK TO COVER SOUTH FACE OF SOUTH WALL WITH 5/8" TYPE X; OK TO COVER SOUTH FACE OF SOUTH WALL WITH 2ND LAYER 5/8" TYPE X; OK TO INSTALL 1ST LAYER 5/8" TYPE X GWB AT CEILING;

Partial Correction
2 Misc 1

ELEVATOR SHAFT -- OK TO COVER WHEN READY: FRAMING + LINER BOARD FULL HEIGHT NORTH, EAST, SOUTH WALLS; EAST WALL 2ND FLOOR 1ST LAYER 5/8" TYPE X; 1ST FLOOR S WALL OK TO HANG 2ND LAYER 5/8" TYPE X GWB; 1ST FLOOR N WALL OK TO HANG BOTH LAYERS 5/8" TYPE X GWB; 2ND FLOOR OK FOR 2ND LAYER 5/8" TYPE X AT N,E,S WALLS;

Partial Correction
3 Misc 1

2ND FLOOR SEPARATION WALL ON (6) FROM (N) TO (Q) WEST FACE 1ST LAYER 5/8" TYPE X GWB OK FOR 2ND LAYER;

Partial Correction
4 Misc 1

PARAPET BETWEEN AC SECTIONS AND BD, MINERAL WOOL AND FIRE PROOFING BETWEEN SHAFT WALLS APPROVED.

Above Ceiling Inspection	Mike Copeland	Partial	Thursday, March 09, 2017
---------------------------------	---------------	---------	--------------------------

Partial Correction

1 Misc 1

OK TO COVER WHEN READY GWB CEILING / SOFFIT FRAMING + ABOVE-CEILING SYSTEMS @ FOLLOWING 1ST FLOOR SPACES: VESTIBULE @ MEN'S & WOMEN'S RESTROOMS 102 / 103; SOFFITS/FACIAS @ C104 LAB, 1-101, 1-117, 1-118; LIGHT COVE @ 1-151; HARD LID SOFFIT FIRST FLOOR AREA C A156

Comments: