

Temporary Certificate of Occupancy

Permit #: PRRES20160496
Address: 3110 SE 3RD TER, LEES SUMMIT, MO 64063
Inspected On: Thursday, March 09, 2017
Inspected By: Khanh Nguyen
Expiration Date: 4/10/2017 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Temporary C of O	Thursday, March 09, 2017

Corrective Action Required:

1	Misc 1	-RAISE WATER METER TO FLUSH WITH GRADE. MAINTAIN METER-LID DISTANCE PER LS STANDARD -INSTALL SEWER CLEANOUT PLUG
---	--------	--