

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20152912, Building Permit - Commercial  
Address: 2751 NE DOUGLAS ST, Unit:T, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Khanh Nguyen	Failed	Thursday, March 09, 2017

### Corrective Action Required

1	Misc 1	<ul style="list-style-type: none"><li>-PROVIDE CITY APPROVED PLAN ON SITE</li><li>-PROTECT ALL PLUMBING PER CODE</li><li>-SECURELY FASTEN ALL MC CABLES WITHIN 12" OF ALL BOXES AND ENCLOSURES AND AT INTERVAL NOT MORE THAN 6 FT</li><li>-SECURE EMT WITHIN 3 FT OF PANEL</li><li>-PROVIDE EM EXIT LIGHTING AND EXIT DISCHARGE</li><li>-BOND ALL METAL BOXES</li><li>-INSTALL BUSHING AT EMT ENTRY INTO PANEL</li><li>-ID GROUNDED CONDUCTOR PER CODE</li><li>-INSTALL PROPER DRAINAGE FITTING PER CODE</li><li>-INSTALL MID-WALL HEIGHT SUPPORT FOR 2" OR SMALLER PVC INSIDE WALL</li><li>-REMOVE ALL CONSTRUCTION DEBRIS OUT OF WALL SPACE</li><li>-VENT PLUMBING FIXTURES PER CODE</li><li>-OPEN PLUMBING INSIDE WALL SPACE</li><li>-SECURELY SUPPORT PEX WATER LINES PER CODE</li><li>-RESTROOM SHALL COMPLY WITH ADA/ANSI 117</li><li>-INSTALL BLOCKINGS FOR GRAB BARS PER ANSI 117</li><li>-VENT BATH FAN</li></ul>
---	--------	--

\*\*\*PLUMBER LICENSED???

**Comments:**