

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20162048, Building Permit - Commercial
Address: 820 NW BLUE PKWY, Unit:H, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Electrical Inspection - Commercial	Mark Harding	Passed	Friday, March 10, 2017

Rough Framing Inspection - Commercial	Mark Harding	Partial	Friday, March 10, 2017
--	--------------	---------	------------------------

Corrective Action Required

1	Misc 1	-ok to rock exterior shell wall per plans -Framing ispection, rooms approved to One-Side 12,15,18,121. do not one side any wall with plumbing.
---	--------	---

Comments: